



# EXAMPLE A Driveway Turnouts


Form # 1 (MCFPOA) Revised 1/30/97



# EXAMPLE B Driveway / Road Turnaround



# EXAMPLE C Driveway Turning Radii



May use minimum 25' inside radius

Must use minimum 28' inside radius

The local fire jurisdiction will consider designs other than those shown above.